

Tollaust Pty Ltd

Lane Cove Tunnel

CO In Tunnel Air Quality Monitoring Validated Report

1st October 2018 – 31st October 2018

Report No.: DAT13895

Report issue date: 07/11/2018

Maintenance contract: MC1072

ECOTECH PTY LTD. ABN: 32005752081

1492 Ferntree Gully Rd, Knoxfield VIC. 3180. AUSTRALIA

Tel No: 1300 364 946 Fax No: 1300 668 763

Email ecotech@ecotech.com WEB www.ecotech.com

This document shall not be reproduced except for in full, without the written approval of Ecotech Pty Ltd.

Lane Cove Tunnel & Military Road E-Ramp


Report No: DAT13895

Tollaust Pty Ltd

Customer Details	
Customer	Tollaust Pty Ltd
Contact name	Melinda Woods
Address	5 Sirius Road, Lane Cove West, NSW 2066
Email	MeWoods@transurban.com
Phone	(02) 8059 6214

Revision History			
Revision	Report ID	Date	Analyst
0	DAT13895	07/11/2018	David Ding

Report by: David Ding



Approved Signatory: Jon Alexander



Table of Contents

Customer Details	2
Revision History	2
Table of Contents	3
List of Figures	4
List of Tables	4
Executive Summary	5
1.0 Introduction	6
2.0 Monitoring and Data Collection.....	6
2.1. Siting Details.....	6
2.2 .Monitored Parameters.....	9
2.3. Data Collection Methods	10
2.3.1. Compliance with Standards	10
2.3.2. Data Acquisition	10
2.3.3. Data Validation.....	11
2.3.4. Reporting.....	11
3.0 Air Quality Goals	12
4.0 Calibrations and Maintenance	13
4.1.Units and Uncertainties	13
5.0 Results	14
5.1. Data Capture	14
5.2. Air Quality Summary	16
5.3. Graphic Representations	17
Report Summary	20
Appendix 1 - Definitions & Abbreviations.....	21

List of Figures

Figure 1: Lane Cove monitoring network.....	8
Figure 2: CO exposure and single point 3 minutes rolling averages for October 2018	17
Figure 3: CO exposure and single point 15 minutes rolling averages for October 2018	17
Figure 4: CO exposure and single point 30 minutes rolling averages for October 2018	18
Figure 5: CO exposure and single point 3 minutes rolling averages from August 2018 to October 2018 (3 monthly trend).....	18
Figure 6: CO exposure and single point 15 minutes rolling averages from August 2018 to October 2018 (3 monthly trend).....	19
Figure 7: CO exposure and single point 30 minutes rolling averages from August 2018 to October 2018 (3 monthly trend).....	19

List of Tables

Table 1: Locations and parameters for In-tunnel open path type air quality monitoring.....	7
Table 2: Parameters measured at the Lane Cove monitoring network.....	9
Table 3: Methods	10
Table 4: Station/Network Air Quality Goals.....	12
Table 5: Units and Uncertainties.....	13
Table 6: Monthly Data Capture for Lane Cove Tunnel & Military Road E-Ramp monitors for October 2018	15
Table 7: Exceedences Recorded for October 2018	16

Executive Summary

The Lane Cove Tunnel is located in Sydney, Australia and is a 3.6 km twin tunnel motorway under Epping Road that links the M2 Motorway at North Ryde with the Gore Hill Freeway at Artarmon. Ecotech Pty Ltd is contracted by Tollaust Pty Ltd to undertake reporting services for the air quality monitoring system inside the tunnel which ensures that the carbon monoxide (CO) levels inside the Tunnel are always kept to within levels and limits stipulated by the Ministers Conditions of Approval (MCoA) for the Lane Cove Tunnel.

Continuous measurements of CO inside the tunnel are recorded, validated and reported to Tollaust Pty Ltd on a monthly basis.

Maintenance and calibrations are performed by a third party contractor.

This report presents validated data for the month of October 2018.

During the reporting period of October 2018, there were no observed exceedences of CO limits stipulated by the Department of Planning inside the tunnel.

1.0 Introduction

Ecotech is an independent company contracted by Tollaust Pty Ltd to undertake in tunnel air quality reporting at the Lane Cove Tunnel.

This report presents the validated data for October 2018.

- Describes air quality measurements;
- Reports any readings above the LCT limits;
- Compares monitoring results;
- Has been quality assured;

2.0 Monitoring and Data Collection

2.1. Siting Details

The CO In tunnel monitoring network consists of

- Twenty eight separate CO monitors attached to the walls and portals of both eastbound and westbound tunnels

Table 1: Locations and parameters for In-tunnel open path type air quality monitoring

Monitoring Location	Parameters Measured
	CO
A	AQS101
B	AQS501
C	AQS502
F	AQS503
G	ACO101
H	AQS504
I	AQS505
J	AQS102
M	ACO102
N	ACO501
Q	AQS103
R	AQS506
S	ACO103
T	ACO502
U	AQS104
V	AQS507
W	ACO401
X	ACO104
Y	AQS401
Z	AQS402
AA	AQS105
AB	ACO801
AC	AQS403
AG	AQS106
AH	ACO503
AI	AQS801
AJ	AQS107
AK	AQS508
TOTAL	28

Non-highlighted rows – tunnel wall monitors; light grey highlighted rows – portal located monitors; dark grey highlighted rows –in ventilation stack monitors

Tollaust Pty Ltd



2.2. Monitored Parameters

Table 2 below details the parameters monitored and the instruments used at the monitoring network. Appendix 1 defines any abbreviated parameter names used throughout the report.

Table 2: Parameters measured at the Lane Cove monitoring network

Parameter Measured	Instrument and Measurement Technique
CO	CODEL TunnelCraft III AQM – Infrared Gas Cell Correlation.

2.3. Data Collection Methods

Table 3 below shows the methods used for data collection. Any deviations from the stated methods are detailed in section 2.3.1.

Table 3: Methods

Parameter Measured	Data Collection Methods Used	Description of Method
CO	Codel Tunnel Master Open Path - infrared	This method involves projecting an infrared beam across a 3 metre section of the tunnel into a reflector and the reflected light is received by a transceiver which measures the specific absorption

Carbon monoxide (CO) levels are measured inside the tunnel using a network of 28 separate CO monitors attached to the walls of both eastbound and westbound tunnels. The monitors measure CO using an analytical method known as non-dispersive infra-red absorption with gas filter correlation. An infra-red beam is projected across a 3 metre section of the tunnel and the amount of infra-red light absorbed by CO molecules in the path of the beam is measured. The quantity of infra-red light absorbed is proportional to the concentration of CO in the path of the beam. The monitors used were specially designed for use in road tunnels where access for routine essential maintenance is restricted by the need to minimise traffic disruption. Similar monitors are widely used in other road tunnels in Australia and worldwide.

The CO method of analysis is similar to the standard method AM-6 outlined in "NSW EPA 2001, Approved Methods for Sampling and Analysis of Pollutants in New South Wales." However the method differs from the standard principally by the use of the open beam type instrument as described above in place of a closed analytical cell and sample delivery pump as typically used in ambient air monitoring stations. This deviation from the standard method has been approved by the Department of Planning on the advice of an independent consultant with specialist expertise in the field of air quality monitoring.

2.3.1. Compliance with Standards

Unless stated below, parameters are monitored at the Lane Cove Tunnel & Military Road E-Ramp stations according to the methods detailed in Table 3 above.

2.3.2. Data Acquisition

Data acquisition is performed using the LCT-MRE Pty Ltd hardware and software and is supplied to Ecotech on a weekly basis and stored at Ecotech's Environmental Reporting Services (ERS) department in Melbourne, Australia. Data samples are logged in 1 minute intervals.

2.3.3. Data Validation

Ecotech ERS maintains two distinct databases containing non-validated and validated data respectively.

The validated database is created by duplicating the non-validated database and then flagging data affected by instrument faults, calibrations and other maintenance activities. The data validation software requires the analyst to supply a valid reason (e.g. backed by maintenance notes, calibration sheets etc) in the database for flagging any data as invalid.

Details of all invalid or missing data are recorded in the Valid Data Exception Tables.

Validation is performed by the analyst, and the validation is reviewed. Graphs and tables are generated based on the validated one minute data.

Validation is based on calibration and maintenance documents provided by Tollaust's appointed contractor at the time of issue.

2.3.4. Reporting

The reported data is in a Microsoft Excel format file named "Data LCT CO In Tunnel October 18_Validated.xls" included as an appendix to this report.

The Excel file consists of 3 Excel worksheets:

1. Cover
2. Max Single Point 3, 15 and 30 m
3. Valid Data Exception Table

The data contained in this report is based on Australian Eastern Standard Time.

All averages are calculated from the one minute data. Averages are based on a minimum of 75% valid readings within the averaging period.

Averaging periods of eight hours or less are reported for the end of the period, i.e. the hourly average 02:00am is for the data collected from 1:00am to 2:00am. One hour averages are calculated based on a clock hour.

3.0 Air Quality Goals

The air quality goals for pollutants monitored at the Lane Cove Tunnel & Military Road E-Ramp monitors are based on the Ministers Conditions of Approval (MCoA) for the Lane Cove Tunnel. The air quality goals are shown in Table 4 below.

Table 4: Station/Network Air Quality Goals

Parameter	Time Period	Exceedence Level	Units	Applicable MCoA
CO	30 minutes rolling averages	50	ppm	MCoA 160
	15 minutes rolling averages	87	ppm	MCoA 160
	3 minutes rolling averages	200	ppm	MCoA 161

4.0 Calibrations and Maintenance

4.1. Units and Uncertainties

The uncertainties for each parameter have been determined by the manufacturer's tolerance limits of the equipment's parameters, and by the data collection standard method.

The reported uncertainties are expanded uncertainties, calculated using coverage factors which give a level of confidence of approximately 95%.

Table 5: Units and Uncertainties

Parameter	Units	Resolution	Uncertainty	Measurement Range
CO	ppm	0.1 ppm	± 1.0 ppm or 2% of span	0 ppm to 200 ppm

5.0 Results

5.1. Data Capture

Data capture is based on 1 minute data, and refers to the amount of available data collected during the report period.

The percentage of data captured is calculated using the following equation:

$$\text{Data capture} = (\text{Reported air quality data} / \text{Total data}) \times 100\%$$

Where:

- Reported air quality data = Number of instrument readings which have been validated through a quality assured process and excludes all data errors, zero data collection due to calibration, failures and planned and unplanned maintenance.
- Total data = Total number of instrument readings since the start of the term assuming no maintenance, errors, loss of data or calibration.

Table 6 below displays data capture statistics for October 2018.

Details of all invalid or missing data affecting data capture are included in the Valid Data Exception Table, see attached Excel file.

Table 6: Monthly Data Capture for Lane Cove Tunnel & Military Road E-Ramp monitors for October 2018

CO	
Monitoring Location	Data Capture (%)
ACO101	100.0
ACO102	100.0
ACO103	92.1
ACO104	99.2
ACO401	90.8
ACO501	100.0
ACO502	98.7
ACO503	98.2
ACO801	99.5
AQS101	100.0
AQS102	100.0
AQS103	100.0
AQS104	100.0
AQS105	99.2
AQS106	-
AQS107	99.2
AQS401	100.0
AQS402	100.0
AQS403	-
AQS501	100.0
AQS502	100.0
AQS503	100.0
AQS504	100.0
AQS505	100.0
AQS506	99.2
AQS507	97.8
AQS508	97.4
AQS801	99.5

5.2. Air Quality Summary

Exceedences of the In Tunnel CO levels observed during the reporting period (if any) are recorded in the table below:

Table 7: Exceedences Recorded for October 2018

Parameter	Time Period	Value of Exceedence	Date of Exceedence	Station
CO	3 minutes rolling averages	-	-	-
	15 minutes rolling averages	-	-	-
	30 minutes rolling averages	-	-	-

5.3. Graphic Representations

Validated 1 minute data for CO were used to construct the following monthly graphic representations.




Figure 2: CO exposure and single point 3 minutes rolling averages for October 2018




Figure 3: CO exposure and single point 15 minutes rolling averages for October 2018




Figure 4: CO exposure and single point 30 minutes rolling averages for October 2018




Figure 5: CO exposure and single point 3 minutes rolling averages from August 2018 to October 2018 (3 monthly trend)




Figure 6: CO exposure and single point 15 minutes rolling averages from August 2018 to October 2018 (3 monthly trend)




Figure 7: CO exposure and single point 30 minutes rolling averages from August 2018 to October 2018 (3 monthly trend)

Report Summary

- During the reporting period of October 2018, there were no observed exceedances of CO limits stipulated by the Department of Planning inside the tunnel.

-----END OF REPORT-----

Appendix 1 - Definitions & Abbreviations

CO Carbon monoxide

ppm Parts per million